

Water Testing Results to Date
Updated: 08/23/2023

As previously communicated to the campus community, water samples have been collected from all occupied buildings on the NJIT campus and analyzed for lead contamination. Additional samples are being collected periodically; following the repair or replacement of plumbing fixtures; the installation of point of use filtration devices; randomly at various campus locations; or in support of specific campus initiatives.

Please note that results are reported in PPB (parts per billion) which is equivalent to microgram per liter (ug/L). ND stands for “None Detected” which means that the results are below the laboratory’s limit of analytical detection. G denotes a grab sample while F denotes a flush sample.

The table below denotes drinking testing at the Sara Ward Daycare Center located at 105 Lock Street.

Drinking Water Sampling Field Sheet
Sampled on: October 6, 2022
Received Results on: October 13, 2022

Building	Location	Notes	Sample Type	Results PPB
Sara Ward	1 st Floor	Sink in Classroom # 1	G	ND
Sara Ward	1 st Floor	Sink in Classroom # 2	G	ND
Sara Ward	1 st Floor	Bathroom between classroom # 1 and # 2 – Right Hand Sink	G	ND
Sara Ward	1 st Floor	Sink in Multipurpose Room	G	ND
Sara Ward	1 st Floor	Sink in Classroom # 3	G	ND
Sara Ward	1 st Floor	Bathroom in Classroom # 3 – Center Sink	G	ND
Sara Ward	1 st Floor	Sink in Classroom # 4	G	ND
Sara Ward	1 st Floor	Bathroom between classroom # 4 and # 5 – Left Hand Sink	G	ND
Sara Ward	1 st Floor	Sink in Classroom # 5	G	ND
Sara Ward	1 st Floor	Sink in Classroom # 6 - Left Hand Sink	G	ND
Sara Ward	1 st Floor	Sink in Classroom # 6 – Right Hand Sink	G	ND
Sara Ward	1 st Floor	Sink in Classroom # 7 (Staff Lounge) - Left Hand Sink	G	ND
Sara Ward	1 st Floor	Sink in Classroom # 7 (staff Lounge) - Right Hand Sink	G	ND
Sara Ward	Field Blank		N/A	ND

Drinking Water Sampling Field Sheet

Sampled on: March 18, 2021

Received Results on: March 25, 2021

Building	Location	Notes	Sample Type	Results PPB
Sara Ward Day Care	Lavatory Sink Boy's Rest Room Left Bowl	Bathroom between rooms 6 and 7 (replace components and retest)	G	ND
Note: The correct location of the above sample is the lavatory sink boy's rest room left bowl located in the bathroom between rooms 4 and 5 – container was inadvertently mislabeled. This is the re-sample of the same location listed below.				

Drinking Water Sampling Field Sheet

Sampled on: February 16, 2021

Received Results on: February 23, 2021

Building	Location	Notes	Sample Type	Results PPB
Sara Ward Day Care	Sink Classroom #6		G	1.3
Sara Ward Day Care	Lavatory Sink Boy's Rest Room Left Bowl	Bathroom between rooms 6 and 7 (replace components and retest)	G	30.3
Note: The correct location of the above sample is the lavatory sink boy's rest room left bowl located in the bathroom between rooms 4 and 5 – container was inadvertently mislabeled.				
Sara Ward Day Care	Sink Classroom # 7		G	2
Sara Ward Day Care	Sink Classroom # 3		G	ND
Sara Ward Day Care	Sink Staff Lounge	Left Bowl	G	ND
Sara Ward Day Care	Sink Staff Lounge	Right Bowl	G	ND
Sara Ward Day Care	Sink Multipurpose Room	Left Sink (large)	G	ND
Sara Ward Day Care	Sink Multipurpose Room	Right Sink (small) (sink removed from service and sign posted)	G	15.3
Sara Ward Day Care	Common Rest Room	Rear Hallway	G	ND
Sara Ward Day Care	Sink Classroom # 2		G	ND
Sara Ward Day Care	Lavatory Sink Rest Room Right Bowl	Bathroom between rooms 1 and 2	G	1
Sara Ward Day Care	Sink Classroom # 1		G	ND
Sara Ward Day Care	Sink Classroom # 5		G	ND
Sara Ward Day Care	Field Blank		N/A	ND

Drinking Water Sampling Field Sheet

Sampled on: November 11, 2020

Received Results on: November 18, 2020

Building	Location	Notes	Sample Type	Results PPB
Sara Ward Day Care	First Floor	Main Wash Sink	G	ND
Sara Ward Day Care	First Floor	Secondary Wash Sink	G	ND
Sara Ward Day Care	First Floor	Drinking Water Cooler	G	ND